



9701 50th Avenue East, Tacoma, WA 98446-5444
Phone: (253) 537-7781 • **Fax:** (253) 536-1759
 service@summitwater.org

BOARD OF DIRECTORS

OFFICERS:

President: Greg Armstrong
 Vice President: Dan Watson
 Treasurer: Mike Craig
 Secretary-Manager: Darryl Scott

TRUSTEES:

Gary Houston
 Jeff Ytreeide
 Robert Pietzke
 Clayton Posey

Summit Water & Supply Company's 2018 Consumer Confidence Report · 2019 Annual Meeting Notice

About Summit Water

We are a member owned, "not-for-profit" corporation, "Group A" water system (State of Washington Department of Health identification #85050V). Services of the corporation are provided to residences, businesses, public entities and other organizations located in the greater Summit/Waller area of Pierce County. There are approximately 5,180 members. The corporation's articles of incorporation and By-laws along with federal, state and local regulations govern the operation of the Company.

The Board of Directors meet twice a month and receives member comments. Summit Water will be glad to provide you additional information about water quality. To obtain this information you may write, e-mail (service@summitwater.org), call (253-537-7781) or drop by our office located at 9701 50th Ave. East, Tacoma, WA. 98446-5444. For more information about the health effects of the listed contaminants in the material provided in this report, call the Environmental Protection Agency hotline at (800) 426-4791.

The Annual Meeting of Summit Water & Supply Company is scheduled for 6:00 PM, Tuesday, April 9, 2019. The meeting will be at the Summit Water & Supply Company's main office, located at 9701 50th Ave. E. (approximately four blocks west of Canyon Rd., on 50th Ave. E. - private roadway).

Voting Status

If you are not on the rolls as the property owner (or legal representative) you cannot vote! If you are a new property owner on the water system, you may wish to contact the office. We can verify the membership records as to the listed property owner. Legal documentation is needed to transfer a membership into the owner's name. This is accomplished by sending Summit Water Co. a copy of any recorded documentation that states the name of the legal owner. The Statutory Warranty Deed is the most often used document. **Addressing the Board of Directors and voting on business matters requires that the membership be in your name.**

Meeting Agenda

- Minutes of the 2018 Annual Meeting
- Treasurer's Report
- Election of Trustee - Position #7
- Report on Company Operations

Water Usage (Increase)

Water consumed during 2018 increased by approximately 4.1 percent when compared to the usage in 2017 (24.5% increase by large use irrigators). The total water pumped from Summit Water sources was 197 million gallons for 2018 with an additional 457 million gallons purchased by wholesale agreement with Lakewood Water District. The source water, (what we pumped along with the purchased water), decreased by approximately 3.8% when compared to the amount of source water pumped in 2017.

Membership Growth

Paid-in membership increased by twenty-five (25) users for 2018. Out of the twenty-five new connections, one was a small commercial connection, two were medium irrigation connections, eight were medium multi-family connections, one was a medium residential connection and the remaining thirteen were small residential connections. There are approximately 5,180 paid-in memberships and roughly 7,100 equivalent residential units (ERUs) being served by Summit Water.

Prsrt Std
 US Postage
 Paid
 DATABAR

Source Protection

For the past 24 years, Summit Water & Supply has continued its development and implementation of a cross-connection control program. This program meets the state cross-connection control regulations. We continue to work closely with the health department and the property owners in our wellhead areas so that everyone works toward protecting this resource. Prudent chemical application practices and disposal methods will keep your groundwater resource pristine. If you observe evidence of the dumping or abandonment of potential contaminants, **you should report it immediately to the Tacoma-Pierce County Health Department.**

Water Quality Monitoring Results

Summit Water collected approximately 200 water samples in 2018 from its sources and throughout the water system. A certified laboratory conducted the analyses on those samples. The results are on file with the Washington Health Department's Drinking Water Program Office and the EPA.

The testing of the sources of supply for the regulated contaminate substances indicated that the **contaminate levels are below** the Maximum Contaminate Levels as established by the EPA.

The items listed below were detected in our water during the 2018 sampling period. All are below the levels allowed by the agencies. Not listed are other potential contaminates that were not detected in any of our tests.

Contaminants	Highest Level Allowed (MCL)	Highest Level Detected	Ideal Goals (MCLG)	Potential Sources of Contaminants
REGULATED AT THE GROUNDWATER SOURCES				
Nitrate	10ppm	3.39ppm	10ppm	Runoff from fertilizer/septic and erosion of natural deposits
REGULATED AT THE DISTRIBUTION SYSTEM				
Total Haloacetic Acids	60ppb	Not Detected	0	Byproduct of drinking water disinfection
TTHM Potential	80ppb	3.20ppb	0	Byproduct of drinking water disinfection
Chloroform	N/A	0.97ppb	0	Byproduct of drinking water disinfection
Bromodichloro-methane	N/A	1.09ppb	0	Byproduct of drinking water disinfection
Chlorodibromo-methane	N/A	0.61ppb	0	Byproduct of drinking water disinfection
Bromoform	N/A	0.53ppb	0	Byproduct of drinking water disinfection
Total Coliform Bacteria	<5% of monthly samples	0%	0%	Naturally present in the environment

Lakewood Water District (through wholesale intertie)

The items listed below are the highest levels detected in the Lakewood Water District's water for the monitoring period of January 1st to December 31st, 2018. Not listed are those volatile organic chemicals, synthetic organic chemicals and herbicides that were not detected.

Microbiological Contaminants	2018				
	Exceeds	Unit of Measure	MCLG	MCL	Potential Sources of Contaminant
Total Coliform Bacteria	No	70 samples/monthly	0	0	Naturally present in environment
Fecal Coliform and E.coli	No	70 samples/monthly	0	0	Human/animal fecal waste
Inorganic Contaminants	Exceeds	Highest Level Detected	MCLG	MCL	Potential Sources of Contaminant
Nitrate	No	1.85ppm	10ppm	10ppm	Fertilizer runoff; leaching from septic tanks; erosion of natural deposits
Arsenic	No	<0.001ppm	0	0.01ppm	Naturally occurring in rocks and soil
Manganese	No	<0.01ppm	0	0.05ppm	Naturally occurring in rocks and soil
Iron	No	<0.1ppm	0	0.3ppm	Naturally occurring in rocks and soil
Volatile Organic Contaminants	Exceeds	Highest Level Detected	MCLG	MCL	Potential Sources of Contaminant
Total Haloacetic Acid	No	not detected	60ppb	60ppb	Byproduct of drinking water disinfection
Trihalomethane Potential	No	6.58ppb	80ppb	80ppb	Byproduct of drinking water disinfection
Chloroform	No	1.45ppb	0	N/A	Byproduct of drinking water disinfection
Bromodichloro-methane	No	2.05ppb	0	N/A	Byproduct of drinking water disinfection
Chlorodibromo-methane	No	2.11ppb	0	N/A	Byproduct of drinking water disinfection
Bromoform	No	0.97ppb	0	N/A	Byproduct of drinking water disinfection

IMPORTANT NOTICE: Cross-Connection Policy

The Washington State Administrative Codes requires purveyors (Summit Water) to protect the public water system from contamination due to cross-connections. This can be accomplished in part, by the development and implementation of a "Cross-Connection Control Program". A cross-connection is defined as any actual or potential physical connection between a public water system or a consumer's water system and any source of non-potable liquid, solid or gas, which could contaminate the potable water supply. In July of 1994, Summit Water's Board of Directors adopted policy 6.12 "Cross-Connection Control Program", which detailed the Company's plan of implementing a "premise isolation" cross-connection program. Premise isolation is defined as a method of protecting a public water system by installation of approved air gaps or approved backflow prevention assemblies at or near the service connection or alternate location acceptable to the purveyor to isolate the customer's water system from the purveyor's distribution system. Summit Water's current cross-connection policy "6.12(R7) Cross-Connection Control Program Policy and Procedures" requires that a premise isolation backflow assembly (assembly) be installed on all new connections to the water system. Other activities occurring on or to a property served by the Company that require the installation of a backflow assembly are based on, but not limited to; sale of the property (processed with or without escrow), transfer of ownership, addition of accessory dwelling unit (ADU) or other structure, change of use of the property, remodeling or additions to a structure, landscape improvements, irrigation installations, water service reactivation, water line modifications/replacement and/or inspections as may be conducted by qualified Company personnel. Since the installation of these assemblies can create a closed system on the private (home) water system, it is recommended that a water expansion tank be installed to accommodate excess water pressure created by thermal expansion. As of the end of 2018, we have approximately 1,850 active connections (roughly 35% of the system) protected by premise isolation backflow assemblies.


For a complete copy of Lakewood Water's CCR, please call the Summit Water office at (253) 537-7781 (or see Lakewood Water's website at www.lakewood-water-dist.org.)

Changing of the Guards

In October of 2018, Richard (Dick) Cook, President of Summit Water & Supply Company, announced that effective October 31, 2018, he would be retiring from the Board of Directors. Dick served on Summit Water's Board of Directors since 1967 and sat as the Company's President for the last 15 years. Throughout his tenure with the Company, Dick served on nearly every committee. Most recently he served as chair on the Personnel and Equipment Committees and as an advisory member on the Finance Committee. Dick is much respected and appreciated by those he knew, worked with and served and his leadership and wisdom will be greatly missed. We thank you for your 50-plus years of service and commitment and wish you a long, happy, healthy retirement.

The Sources of Your Supply

Summit Water maintains a total of seven (7) well sites with system source water being supplied by four (4) wells and a wholesale connection with Lakewood Water District. The current wholesale contract allows for a maximum transfer of 2.0 million gallons per day (MGD). Summit Water continues its discussions with Lakewood Water District in an effort to secure an additional 1.0 MGD, which would bring our maximum wholesale contract total to 3.0 MGD (1,095,000,000 gallons annually) and provide a pumping capacity of approximately 2,080 gallons per minute. Our storage facilities consist of three (3) standpipe tanks and two (2) ground level tanks with a combined storage capacity of approximately 7.0 million gallons. Potable water and fire flow are supplied through approximately 110 miles of water pipe ranging in size from 2 to 16 inches. The system is operated as a gravity fed system, which means water flows in and out of the standpipe tanks to meet system demand as well as maintaining adequate system pressure. If you have any questions regarding how the system operations please give us a call at (253) 537-7781 or email us at service@summitwater.org and we will have the appropriate personnel respond to your request.



Water Use Efficiency Program

In September 2014, Summit Water advertised and held a public meeting to establish Water Use Efficiency goals as outlined by the State Health Department. Two of the goals that were set at this meeting were to reduce our Peak Day Demand (PDD) per users by at least 0.25% based on a six-year rolling average and to reduce our distribution system leakage to 10% or less based on a three-year rolling average. Our six-year rolling average goal for 2018 was to have reduced our PDD per users to at least 539.5 gallons per day (gpd). Our actual PDD per users for 2018 was 548.5 gallons per day, which did not meet our established goal for 2018. Total water produced/purchased for 2018 was 653,961,119 gallons while metered/accounted for water for the same period was 597,186,504. This resulted in a "Distribution System Leakage" (DSL) or unaccounted for water loss of 8.7% (56,774,615 gallons) for 2018 compared to 12.5% (85,158,944 gallons) for 2017. Based on our average distribution leakage for 2016 (11.9%), 2017 (12.5%) and 2018 (8.7%) our three-year rolling distribution system leakage average is 11.0%.

Water Conservation

With Summer soon approaching, here are some useful websites to help you not only conserve water but save some cash as well.

www.h2ouse.org » www.getwise.org

www.americanwater.com » www.irrigation.org

Safe Drinking Water Hotline

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Hotline **(1-800-426-4791)**.

Immunocompromised Persons

Some people may be more vulnerable to contaminants in drinking water than the general population. Immunocompromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA and the federal Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the EPA's Safe Drinking Water Hotline (1-800-426-4791) between the hours of 6a.m. and 2 p.m. Pacific Time.

Chlorine Disinfection Byproducts

Total Trihalomethanes (TTHM) and Haloacetic Acids (HAA5) are a family of chemicals formed when a disinfectant such as chlorine is added to the water supply. The maximum level permitted for TTHM is 80 parts per billion (ppb) and for HAA5 the maximum level is 60 ppb. Disinfection is an important and necessary step in the supply of tap water, which helps to protect against harmful bacteria and other living organisms that may contaminate the water. Chlorine is the most widely used and approved disinfectant in the United States. Summit Water uses chlorine in a gaseous form for the disinfection of the water supply. There are no contaminants of the water supply coming from the wells. The primary purpose for chlorine addition is for potential contamination of the water distribution system (water mains) up to your meter.

Important Definitions

- **Maximum Contaminant Level (MCL).** The highest level of a contaminant that is allowed in drinking water.
- **Maximum Contaminant Level Goal (MCLG).** The level of a contaminant in drinking water below which there is no known or expected risk to health.
- **Treatment Technique.** If a contaminant exceeds the maximum contaminant level, EPA may require the water system to use a treatment technique. A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.
- **Action Levels.** An Action Level is the concentration of a contaminant, which triggers treatment or other requirements, which a water system must follow.
- **Part per million; part per billion.** One part per million is the equivalent of 1/2 of a dissolved aspirin tablet in a full bathtub of water (approximately 50 gallons). One part per billion is equivalent to 1/2 of a dissolved aspirin tablet in 1,000 bathtubs of water (approximately 50,000 gallons).

Measurements

Water is sampled and tested throughout the year. Contaminants are measured in parts per: million (ppm), billion (ppb), trillion (ppt) and even parts per quadrillion (ppq).

Drinking Water Quality

This is the 20th report describing Summit Water & Supply Company's (Summit Water) drinking water sources, quality testing and programs that protect the quality of the water supply. This publication conforms to a federal regulation requiring water utilities to **provide this information annually**. The last report was provided to the members and customers in June of 2018. Although the report format may look the same as prior reports there is specific information and statements required by statute. This report covers the year 2018. The report's due date for delivery to every consumer of water delivered by the Summit Water system is July 1 of each year.

The United States Environmental Protection Agency (EPA) and the Washington Health Department's Drinking Water Program Division (DOH) are the agencies responsible for establishing drinking water quality standards. To ensure your tap water is safe to drink, EPA and DOH prescribe regulations stating the allowable limit for specific contaminants the water may contain. We make an effort to balance your "right to know" against the sheer volume of information that we can provide. Our website provides a method to get information out in a cost effective way.

Summit Water goes beyond what is required by these agencies to provide quality water to your home or business, through increased monitoring and placing into practice protection methods that further reduce the risk of contamination.

Water quality monitoring reports are submitted, by Summit and also directly from the testing laboratory, to the DOH who then provides the information to the EPA. The agencies verify our compliance with the many regulatory standards and testing protocols required to assure safe drinking water. **For this reporting period in 2018, the water we provided met the established Maximum Contaminate Level (MCL) water quality standards.**

Additional Water Quality Information

All samples taken at our source wells and throughout our system tested below the minimum levels acceptable to the EPA and the DOH. Wells are also the source of water for the Lakewood Water District (LWD) system. Water purchased from LWD is supplied to Summit Water at a higher level of chlorine residual than what is normally maintained on our system. The blending of the water supplies from the two water systems results in water characteristics, which are not uniform throughout the Summit Water distribution system. This is most noticeable in the Waller Road area.

Other Things to Know

Chlorine residuals are maintained throughout the distribution system, and sampling is performed daily to ensure the water has the recommended residual. Certified personnel monitor the chemical addition to the water at the well sites. They also perform on-site tests and collect samples including, but are not limited to, the following:

Daily	Chlorine residuals, pH and temperature
Semi-Monthly	Bacteria (total coliform)
Annually	Nitrates
EPA Directed (3 Year Cycle)	Inorganic, volatile organic contaminants, synthetic organic contaminants, radioactivity, lead, copper and arsenic

All new construction and repair work performed on the water system infrastructure is treated with chlorine. The water is tested for purity by a state approved laboratory prior to these facilities providing water to you the consumer.

EPA states, "The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- **Microbial contaminants**, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- **Inorganic contaminants**, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.
- **Pesticides and herbicides**, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
- **Organic chemical contaminants**, including synthetic and volatile organic chemicals, which are byproducts of industrial processes and petroleum production, and can, also come from gas stations, urban storm water runoff and septic systems.
- **Radioactive contaminants**, which can be naturally occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration regulations establish limits for contaminants in bottled water, which must provide the same protection for public health."