

# TYPICAL FIRE HYDRANT INSTALLATION

## SIDEWALK TYPE INSTALLATION

DRAWING IS SUBJECT TO CHANGE WITHOUT NOTICE. CONTACT SUMMIT WATER FOR LATEST DETAILS.

### NOTES:

- 1 FIRE HYDRANT SHALL BE 3' MIN. FROM ANY OBSTRUCTION.
- 2 ALL FIRE HYDRANT INSTALLATIONS SHALL CONFORM TO THE FITTING SIZES AND THREAD REQUIREMENTS OF FIRE DISTRICT'S NO. 4 AND/OR NO. 9 w/ 5" Stortz Adapter
- 3 HYDRANTS SHALL BE MUELLER, IOWA OR APPROVED EQUAL.

